
1 Supplementary Information

2

3 Updated hourly emissions factors for Chinese power plants
4 showing the impact of widespread ultra-low emissions
5 technology deployment

6 *Xiao Liu[†], Xing Gao[†], Xinbin Wu[‡], Weilin Yu[†], Lulu Chen[§], Ruijing Ni[§],*
7 *Yu Zhao^{||}, Hongwei Duan[‡], Fuming Zhao[‡], Lilin Chen[‡], Shengming*
8 *Gao[‡], Ke Xu[†], Jintai Lin^{* §}, Anthony Y. Ku^{*, †, ⊥}*

9 [†]National Institute of Clean-and-Low-Carbon Energy, Beijing 102211,
10 China

11 [‡]Shenhua Geological Exploration Company, Shenhua Environment
12 Remote Sensing and Monitoring Center, Beijing 102211, China

13 [§]Laboratory for Climate and Ocean-Atmosphere Studies, Department of
14 Atmospheric and Oceanic Sciences, School of Physics, Peking
15 University, Beijing 100871, China

16 ^{||}State Key Laboratory of Pollution Control & Resource Reuse and
17 School of the Environment, Nanjing University, 163 Xianlin Ave.,
18 Nanjing, Jiangsu 210023, China

19 [⊥]NICE America Research, 2091 Stierlin Ct, Mountain View, CA 94043, USA

20 Number of pages:26

21 Number of figures:2

22 Number of tables:7

23 **S1. ULE Implementation in China’s power sector**

24 All power plants that can “afford” ULE retrofitting cost are required to complete the
25 process by 2020. Some “small” boilers and CFB units do not have to install ULE.¹ In
26 some heavy polluted regions like BTH, regional air pollution control measures apply
27 to all coal-fired power boilers larger than 100 MW. This presents a numerical
28 threshold for small units and includes CFB units. Boilers with larger capacity should
29 finished ULE retrofitting before October 2017, including CFB boilers.² In certain
30 designed “environmentally important regions”, coal-fired power units without ULE
31 will be shut down by Jan of 2019.²

32 In addition, an incentive of 1 cent/kWh for units finishing ULE retrofitting before Dec
33 2016, and 0.5 cent/kWh for units finishing ULE retrofitting after 2016 has motivated
34 some power plants with small boilers or CFB units to also perform ULE retrofits. This
35 has occurred most frequently in regions with high levels of air pollution, including
36 BTH, Shandong, Shanxi, Henan, and the Yangtze River Delta.

37 Altogether, we estimate that the combined impact will cover 90% of coal-fired power
38 plants by the end of 2020.

39 **S2. Location and characteristics of power units and ULE technologies**

40 All raw data for EF calculations in this paper were collected from the CEMS of
41 Shenhua Group (now merged with Guodian Group to form China Energy Investment
42 Corporation). Shenhua's CEMS, the first company-based CEMS in China, was
43 developed in the period from Oct 2012 through 2013 for digital management of
44 emissions control, and started its formal operation in January 2014. By the end of
45 2017, Shenhua's CEMS has recorded the company's emission-related data from 162
46 power units and 131 other industrial boilers. The CEMS data includes daily records of
47 coal consumption and sulfur content, and high-frequency real time data on pollutant
48 concentrations, flue gas flow rate, and power load (i.e., electricity or standard vapor
49 generation).

50 Figure S1 shows the locations of 17 power plants considered for this study, which are
51 located across China. Table S2 lists the 38 units from 17 power plants, their
52 geographical locations, nameplate generation capacity, emissions control
53 technologies, and the date ULE technologies were installed at the plant. Plants are
54 grouped by geographic region and type (i.e., with or without heat cogeneration).
55 Eighteen power-only units and twenty electricity and heat cogeneration units are
56 considered.

57 The equipment for a number of distinct configurations for ULE technologies at power
58 units surveyed here are representative of the Chinese power sector. Low NO_x burner
59 (LNB) and selective catalytic reduction (SCR) are used for NO_x control. SCR
60 equipment had already been installed in all units before retrofitting with ULE

61 technologies; LNB equipment was present at a few units as well; and ULE retrofit
62 improved the efficiencies of these systems. These different configurations are
63 representative of the situation across the China power sector.

64 For SO₂ removal, several ULE technologies were used across the power plants in this
65 study. For plants near the ocean, seawater flue gas desulfurization (SFGD) is an
66 ideal method for SO₂ control considering both cost and performance.
67 Limestone-gypsum wet flue gas desulfurization (WFGD) systems offer reduction
68 efficiencies at 95-99%, and have already been deployed at many systems before
69 upgrading by ULE technologies; the upgrades typically involved optimizing the flow
70 fields for flue gas and liquid contact leading to removal efficiencies at 98% or higher.
71 Advanced single column WFGD systems can ensure compliance with SO₂ emissions
72 standards as long as the sulfur content in the input coal is less than 1.25%. For coal
73 with higher sulfur content coal, double column systems are required.³

74 For PM removal, power plants often combine different technologies to reach the ULE
75 emissions standard. In total, there are six different configurations for PM control
76 across the power plants in this study (Table S2). The most commonly used technology
77 for PM removal was the dry electrostatic precipitator (ESP). All units had ESPs
78 installed before retrofitting with ULE technologies. Upgrades typically replaced the
79 electric drive with a high-frequency source. In several plants, these systems were
80 combined with a low temperature economizer (LTE) to reduce the flue gas
81 temperature and improve the capture efficiency of the ESP. This configuration is

82 referred to as a low-low temperature electrostatic precipitator (LLT-ESP). For plants
83 using higher ash content coal, wet electrostatic precipitators (WESP) were added at
84 the end of the treatment train to remove fine, sticky particles and droplets. Although
85 WESP systems are relatively expensive, they are well-suited to PM removal when the
86 flue gas temperature is close to the dew point.³ In addition, there is also a synergistic
87 benefit in PM removal by WFGD and SFGD – for example, a previous study
88 suggested an additional 30–60% reduction in PM at some plants with both WFGD
89 and SCR.⁴

90 One emerging technology to reduce both SO₂ and PM has been introduced by Beijing
91 State Power Environmental Protection Company (SPC) at some plants in China. The
92 technology uses advanced spray nozzles, turbulent mixing and centrifugal separation
93 to simultaneously drive the desulfurization reaction and efficiently remove SO₂ to
94 below 35 mg/m³ and PM to below 5 mg/m³.

95 **S3. Reliability of flue gas flow rate and pollution concentration measurements**

96 Several steps were taken to ensure the quality of flue gas flow rate measurements for
97 the units studied here. First, China Energy strictly enforces the rules established by
98 the Chinese government to set up automated measurement sensors. Each sensor was
99 installed in the horizontal pipe at the inlet of the stack, and the distance between the
100 sensor and the pipe wall was at least 1.2 m.⁵ The sensors measure gas velocity and the
101 flow rate is calculated from the velocity and pipe cross-sectional area. Second, when

102 setting up the sensors, the automated measurements of flow rates were compared to
103 independent manual measurements made using pitot tubes by the Environmental
104 Protection Agencies of local governments to ensure data quality. Data from the
105 automatic sensors were only accepted if their measured flow rate values agreed,
106 within acceptable limits, to manual calibration measurements. For measured flow
107 rates above in terms of flow velocity above 10 m/s, the limit is agreement to within
108 10%. For measured flow rates below 10 m/s, the acceptance threshold was 12%.⁶ For
109 nine of the 38 units, the requirements were stricter: within 5% for rates above 10 m/s
110 and within 8% for rates below 10 m/s. These bounds establish the uncertainty in the
111 data. The calibration procedure involves not less than five calibration measurements
112 for each sensor a day for four or more continuous days; the sensor and manual
113 measurements must agree to within the target threshold for every measurement during
114 this interval. Unacceptable sensors were replaced until the accuracy requirements
115 were fulfilled. As shown in **Table S6**, all sensors in the units studied here met the
116 requirements. Finally, the calibration was checked every three months with manual
117 measurements. In all cases, the sensors studied here met the requirements.

118 The pollution concentration measurements were also validated under rigorous
119 independent tests by the Environmental Protection Agencies of local governments
120 when the sensors were set up, as was done for the flow rate measurements. Pollution
121 control sensors are checked using independent manual measurements on a quarterly
122 basis to ensure the accuracy of the automated measurements.

123 In response to requirements from the central government, China's coal-fired power
124 plants have widely installed CEMS since 2007.^{7,8} Data from pollution concentration
125 measurements reported in the CEMS have formed the basis for many studies.⁹⁻¹²

126 **S4. Comparison our post-ULE emissions factors with the literature**

127 Table S7 compares our EF results with those in the literature for Chinese power plant
128 emissions. Our results are post-ULE temporal average EF grouped by configuration of
129 the ULE technologies at the 38 units. They are thus slightly different from the results
130 of ULE retrofitting effects with ULE on EF for 25 units. Overall, our EF are lower
131 than those in the literature, which represent years before 2017, by a factor of 8–23 for
132 NO_x, 2–80 for SO₂, and 10–120 for PM. The magnitude of improvement depends on
133 ULE configurations, among other factors.

134 As shown in Table S7, in the widely used multi-resolution emission inventory for
135 China (MEIC), the most recent explicit information for EF of Chinese coal-fired
136 power plants corresponds to 2010.¹³ Using the latest power sector emissions in
137 MEIC¹⁴ and China's annual coal consumption data,^{15,16} we derived national average
138 EF for 2015 and 2016 corresponding to MEIC emissions. These MEIC-derived values
139 for 2015–2016 may be slightly overestimated because the power sector emissions in
140 MEIC include contributions from a small number of natural gas-fired power plants.
141 Despite this limitation, Table S7 shows a clear decreasing trend in the MEIC EF over
142 time, indicating that the effects of retrofitting with ULE technologies can be seen in

143 their data sets. With retrofitting across the entire power sector expected to finish by
144 2020, the average EF in 2020 should be an order of magnitude lower than in 2014.

145 For NO_x, our post-ULE EF is 0.48±0.11 g/kg averaged across time and the 38 units
146 (Table S7). This value is consistent with the range of 0.23-0.73 g/kg reported by Ma
147 et al. for 2015.¹⁷ Our average EF value is lower by a factor of 8–23 than those in the
148 INTEX-B inventory for 2006,¹⁸ the CEPD for 2010,¹³ the pre-2010 values in Zhao et
149 al.,¹⁹ and the MEIC values for 2015–2016. These EF differences are substantially
150 larger than the difference before and after retrofit in our paired data for the 25 units
151 (see Fig. 2). This is mainly because all units studied here had SCR and (sometimes)
152 LNB installed prior to retrofit, which is not always the case for other power units
153 implicitly included in existing inventories.

154 For SO₂, our post-ULE temporal average EF for the 38 units are 0.02±0.01, 0.1±0.02
155 and 0.27 ± 0.09 g/kg for SFGD, SPC and WFGD, respectively (Table S7). For
156 comparison with the literature, we also express these values as a function of the sulfur
157 content (0.05-0.5 g S/kg fuel, after dividing the EF value by the annual average
158 percentage sulfur content at each unit). Our post-ULE EF are much lower than
159 INTEX-B (15.6 g/kg for 2006), CEPD (4.89 g/kg for 2010), Zhao et al. (0.9 g/kg
160 before 2010, for a few power plants with WFGD), and derived MEIC values (3.39
161 g/kg for 2015 and 2.23 g/kg for 2016).

162 For PM, our EF range from 0.01 to 0.04 g/kg, depending on the ULE configuration
163 (Table S7). Again, we express these values as a function of the percentage ash content
164 (0.0016-0.0028 g ash /kg fuel, in the same manner as done for SO₂ EF) to facilitate
165 the comparison with the literature. Our post-ULE EF are lower by at least one order of
166 magnitude than the values in INTEX-B (1.2 g/kg for PM_{2.5} in 2006), CEPD (0.83 g/kg
167 for PM₁₀ in 2010), Zhao et al. (0.0231A g/kg for PM before 2010, for a few power
168 plants with ESP+WFGD), and derived MEIC values (1.13 g/kg for PM in 2015 and
169 1.07 g/kg for 2016).

170 We further compare our EF results with those for natural gas-fired power plants in
171 several countries/regions in the literature.²⁰⁻²³ These studies presented the EF values in
172 terms of emissions per kWh of electricity generated (g/kWh). We thus converted the
173 EF to emissions per unit of standard coal burned (g/kg) using the annual average
174 standard coal burned per kWh of electricity in 2015 in China (0.315 kg/kWh), for
175 comparison with our calculated EF. As shown in Table S7, our average post-ULE EF
176 value for NO_x (0.48 g/kg) is higher than the EF for gas-fired plants equipped with
177 SCR by 23-300%,^{20,21,23} although it is lower than the value in Song et al. for
178 LNB-equipped gas-fired plants in China in 2014 (2.15 g/kg).²² For SO₂, our EF for
179 units equipped with WFGD (0.27 g/kg) was higher than that for gas-fired plants
180 (0.005–0.197 g/kg), whereas our EF for SPC (0.1 g/kg) and SFGD (0.02 g/kg) were
181 lower than Spath et al. (0.197 g/kg). For PM, our EF values (0.01–0.05 g/kg) can be
182 higher or lower than the EF for gas-fired plants (0.0003–0.028 g/kg). Our results show

183 that power plants equipped with the most emission-stringent ULE technologies are
184 approaching natural gas-fired power plants in emissions performance.

185 **References**

- 186 1. National development and reform commission of China, Ministry of
187 environmental protection of China, National energy administration of China. The
188 upgrade and transformation action plan for coal-fired power energy saving and
189 emission reduction(2014-2020).2014.
190 http://www.gov.cn/gongbao/content/2015/content_2818468.htm.
- 191 2. Ministry of environmental protection of China, regional government, Air pollution
192 control strengthen measures over Beijing-Tianjin-Hebei region (2016-2017).
193 2016.
- 194 3. Xu, Y.; Liu, X.; Cui, J.; Chen, D.; Xu, M.; Pan, S.; Zhang, K.; Gao, X. Field
195 measurements on the emission and removal of PM_{2.5} from coal-fired power
196 stations: 4. PM removal performance of wet electrostatic precipitators. Energy and
197 Fuels. 2016, 30, 7465-7473.
- 198 4. Li, Z.; Jiang, J.; Ma, Z.; Fajardo, O. A.; Deng, J.; Duan, L. Influence of flue gas
199 desulfurization (FGD) installations on emission characteristics of PM_{2.5} from
200 coal-fired power plants equipped with selective catalytic reduction (SCR).
201 Environmental Pollution. 2017, 230, 655-662.

-
- 202 5. Environmental protection administration of China. Specifications for continuous
203 monitoring of flue gas emitted from stationary sources. HJ/T 75-2007. 2007.
- 204 6. Environmental protection administration of China. Specifications and test
205 procedures for continuous monitoring system for SO₂, NO_x and particulate matter
206 in flue gas emitted from stationary sources. HJ/T 76-2007. 2007.
- 207 7. Environmental protection administration of China. Departmental rule 241:
208 development plans for automatic environmental monitoring capacity building
209 projects at the state-controlled key polluting sources. Beijing, 2007.
- 210 8. Zhang, X. H.; Schreifels, J. Continuous emission monitoring systems at power
211 plants in China: Improving SO₂ emission measurement. *Energy Policy*. 2011, 39,
212 7432-7438.
- 213 9. Bo, X.; Wang, G.; Wen, R.; He, Y. J.; Ding, F.; Wu, C. Z.; Meng, F. Air pollution
214 effect of the thermal power plants in Beijing-Tianjin-Hebei region. *China
215 Environmental science*. 2015, 35, 364-373.
- 216 10. Cui, J. S.; Qu, J. B.; Bo, X.; Chang, X. Y.; Feng, X.; Mo, H.; Li, S. P.; Zhao, Y.;
217 Zhu, F. H.; Ren, Z. H. High resolution power emission inventory for China based
218 on CEMS in 2015. *China Environmental science*. 2018, 38, 2062-2074.

-
- 219 11. Bo, X.; He, Y. J.; Shang, G. D.; Ding, F.; Zhao, X. H. Development and
220 application of the national pollutant emission inventory database system with
221 CEMS. *Environmental Monitoring & Assessment*. 2014, 8, 105-113.
- 222 12. Zhang, L.; Zhao, T. L.; Gong, S. L.; Kong, S. F.; Tang, L. L.; Liu, D. Y.; Wang,
223 Y. W.; Jin, L. J.; Shan, Y. P.; Tan, C. H.; Zhang, Y. J.; Guo, X. M. Updated
224 emission inventories of power plants in simulating air quality during haze periods
225 over East China. *Atmos. Chem. Phys.* 2018, 18, 2065–2079.
- 226 13. Liu, F.; Zhang, Q.; Tong, D.; Zheng, B.; Li, M.; Huo, H.; He, K. B.
227 High-resolution inventory of technologies, activities and emissions of coal-fired
228 power plants in China from 1990 to 2010. *Atmos. Chem. Phys.* 2015, 15,
229 13299-13317.
- 230 14. Zheng, B.; Tong, D.; Li, M.; Liu, F.; Hong, C. P.; Geng, G. N.; Li, H. Y.; Li, X.;
231 Peng, L. Q.; Qi, J.; Yan, L.; Zhang, Y. X.; Zhao, H. Y.; Zheng, Y. X.; He, K. B.;
232 Zhang, Q. Trends in China's anthropogenic emissions since 2010 as the
233 consequence of clean air actions. *Atmos. Chem. Phys. Discuss.* 2018,
234 <https://doi.org/10.5194/acp-2018-374>.
- 235 15. National Bureau of Statistics. *China energy statistical yearbook 2015*, China
236 statistics press: Beijing, 2016.

-
- 237 16. National Bureau of Statistics. China energy statistical yearbook 2016, China
238 statistics press: Beijing, 2017.
- 239 17. Ma, Z.; Deng, J.; Li, Z.; Li, Q.; Zhao, P.; Wang, L.; Sun, Y.; Zheng, H.; Pan, L.;
240 Zhao, S. Characteristics of NO_x emission from Chinese coal-fired power plants
241 equipped with new technologies. *Atmos. Env.* 2016, 131, 164-170.
- 242 18. Zhang, Q.; Streets, D. G.; Carmichael, G. R.; He, K. B.; Huo, H.; Kannari, A.;
243 Klimont, Z.; Park, I. S.; Reddy, R.; Fu, J. S.; Chen, D.; Duan, L.; Lei, Y.; Wang,
244 L. T.; Yao, Z. L. Asian emissions in 2006 for the NASA INTEX-B mission.
245 *Atmos. Chem. Phys.* 2009, 9, 5131-5153.
- 246 19. Zhao, Y.; Wang, S.; Nielsen, C. P.; Li, X.; Hao, J. M. Establishment of a database
247 of emission factors for atmospheric pollutants from Chinese Coal-fired power
248 plants. *Atmos. Env.* 2010, 44, 1515-1523.
- 249 20. Spath, P. L.; Mann, M. K. Life cycle assessment of a natural gas combined cycle
250 power generation system. *British Journal of Sports Medicine.* 2000, 42, 300-303.
- 251 21. Jarre, M.; Noussan, M.; Poggio, A. Operational analysis of natural gas combined
252 cycle CHP plants: Energy performance and pollutant emissions. *Applied Thermal*
253 *Engineering.* 2016, 100, 304–314.
- 254 22. Song, Q. B.; Wang, Z. S.; Li, J. H.; Duan, H. B.; Yu, D. F.; Liu, G. Comparative
255 life cycle GHG emissions from local electricity generation using heavy oil, natural

256 gas, and MSW incineration in Macau. *Renewable and Sustainable Energy*
257 *Reviews*. 2018, 81, 2450–2459.

258 23. Wang, S. M.; Liu, J. Z.; Economic and environmental comparison of clean
259 coal-fired power and gas turbine power. *China coal*. 2016, 42, 5-13.

260

261

262

263

264

265

266 **Table S1. Regulatory emissions limits for NO_x, SO₂, and PM in coal-fired power**
267 **plants**

	ULE limits (mg/Nm ³) ^a	MEP 2012 limits (mg/m ³)		
		Special areas	Newly built units	Existing units
NO _x	50	100	100	100
SO ₂	35	50	100	200
PM	5	20	30	30

^a“m³” means at the standard state (1 atm and 273.15 K).

268

269

270 **Table S2. Sampled power units and ULE configurations**

No.	Units	Capacity		ULE configuration		Retrofit
		(MW)	NOx removal	SO2 removal	PM removal	date
Electricity generation only units						
BTH region						
1	DG3	328.5	LNB+SCR	WFGD	LLT ESP+WFGD	2014.5
2	DG4	328.5	LNB+SCR	WFGD	LLT ESP+WFGD	2014.3
Northwest China						
3	YH1	660	LNB+SCR	WFGD	ESP+WFGD	2015.3
4	YH2	660	LNB+SCR	WFGD	ESP+WFGD	2015.3
Central China						
5	MJ1	600	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.5
6	M2	600	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.4
7	XZ2	1000	LNB+SCR	WFGD	ESP+WFGD	2016.1
East China						
8	JH1	320	LNB+SCR	WFGD	LLT ESP+WFGD+WESP	2016.6
9	JH2	320	LNB+SCR	WFGD	LLT	2015.8

						ESP+WFGD+WESP
10	ZS4	350	LNB+SCR	SFGD	ESP+SFGD+WESP	2014.6
11	TC7	630	LNB+SCR	SPC	LLT ESP+SPC+WESP	2015.11
12	TC8	630	LNB+SCR	SPC	LLT ESP+SPC+WESP	2016.11
13	AQ3	1000	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.5
14	AQ4	1000	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.6
15	HS3	1000	LNB+SCR	SPC	SPC	2015.12
16	HS4	1000	LNB+SCR	SPC	SPC	2015.12
17	WZ1	1050	LNB+SCR	SPC	SPC	2015.2
18	WZ2	1050	LNB+SCR	SPC	SPC	2015.9

Electricity and heat cogeneration units

BTH region

19	QD1	215	LNB+SCR	SFGD	ESP+SFGD	2015.7
20	QD2	215	LNB+SCR	SFGD	ESP+SFGD	2015.4
21	QD3	320	LNB+SCR	SFGD	ESP+SFGD	2014.12
22	QD4	320	LNB+SCR	SFGD	ESP+SFGD	2015.7
23	SH1	350	LNB+SCR	WFGD	LLT	2014.7

					ESP+WFGD+WESP	
24	SH2	350	LNB+SCR	WFGD	LLT ESP+WFGD+WESP	2014.11
25	SH3	300	LNB+SCR	WFGD	LLT ESP+WFGD	2015.12
26	SH4	300	LNB+SCR	WFGD	LLT ESP+WFGD+WESP	2015.7
27	PS1	530	LNB+SCR	WFGD	ESP+WFGD	2015.11
28	PS2	530	LNB+SCR	WFGD	ESP+WFGD	2015.12
29	DZ3	660	LNB+SCR	WFGD	ESP+WFGD+WESP	2014.12
30	DZ4	660	LNB+SCR	WFGD	ESP+WFGD+WESP	2014.12
North China						
31	ZD1	330	LNB+SCR	WFGD	ESP+WFGD	2016.7
32	ZD2	330	LNB+SCR	WFGD	ESP+WFGD	2016.6
33	ZD3	330	LNB+SCR	WFGD	ESP+WFGD	2015.9
34	ZD4	330	LNB+SCR	WFGD	ESP+WFGD	2015.11
Northeast China						
35	BD1	600	LNB+SCR	WFGD	ESP+WFGD+WESP	2016.8
36	BD2	600	LNB+SCR	WFGD	ESP+WFGD+WESP	2016.8

Central China

37	CD3	660	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.11
38	CD4	660	LNB+SCR	WFGD	ESP+WFGD+WESP	2015.1

272 **Table S3. Monitoring methods and sensors used in field measurements in**
 273 **different units**

	Analytical method ^a	Unit	Accuracy
Concentrations of SO ₂ and NO _x	Non-Dispersive	DG3,DG4,YH1,	
	Infrared Absorption (NRIR)	YH2,AQ1,AQ2,CD3,CD4, ZD1, ZD2, ZD-3, ZD-4	±1%
	Non-Dispersive	JH1, JH2, BD1, BD2, PS1, PS2, MJ3,	±1%
	InfraRed (NDIR)	MJ4	
	Infrared Analysis (FTIR)	ZS4, TC7, TC8	≤±2.0 %
	Ultraviolet-visible light Absorption (UV-vis)	XZ2	±2.0 %
Concentration of PM	Pulsed Ultraviolet Fluorescence Analysis	SH1, SH2, SH3, SH4	±0.5%
	Laser forward scattering	WZ1, WZ2, YH1, YH2, AQ3, AQ4, ZS4, TC8, JH2, PS1, PS2, MJ3, MJ4, ZD1, ZD2, ZD-3, ZD-4	≤±2.0%
	Laser back scattering	CD3, CD4, QD1, GD2, QD3, QD4	≤±2.0%
	Double-path turbidity	JH1	≤±2.0%

	monitoring		
	Turbidity monitoring	XZ2	$\leq \pm 2.0\%$
	Ac coupled charge induction	BD1, BD2	
	Light-scattering analysis	TC7	
	Pitot tube method	YH1, YH2, ZS4, JH7, JH8, CD3, CD4, MJ1, MJ2, XZ2, AQ3, AQ4	$\leq \pm 0.5-5\%$
	Ultrasonic flowmeter	DZ3, DZ4	$\pm 0.25\%$
Flow rate of flue gas	Thermal mass flowmeter	HS3, HS4, SH1, SH2, SH3, SH4, PS1, PS2	$\pm 0.5\%$
	Needle valve flowmeter	TC7, TC8	$\pm 1\%$
	AC charge flow meter	BD1, BD2	$\pm 1\%$

274 a: Linear error limit of each sensor:

275 Maximum allowable sensor zero drift: $\pm 2\%$ in 24 hours for pollutant concentration, and $\pm 3\%$ in 24
276 hours for flue gas flow rate.

277 Maximum allowable sensor span drift: $\pm 2.5\%$ in 24 hours for pollutant concentration, and $\pm 3\%$ in
278 24 hours for flue gas flow rate.

279 Repeatability of flue gas flow rate measurement: $\pm 1\%$ in 24 hours.

280 All plants make field calibration for all sensors of CEMS every 15 days.

281

Table S4. Annual average coal quality consumed at each sampled unit

No	Units	Region	Capacity ^a		S ^b (%)			V ^c (%)	Coal consumpt ion rate ^d (g/kWh)	Low heat value ^e (MJ/kg)
			Power (MW)	Vapor (ton St. vapor/hour)	2015	2016	2017			
Electricity generation only units										
1	DG3	BTH	328.5	1100	0.45	0.4	13.23	306.7	20.67	
2	DG4	BTH	328.5	1100	0.43	0.4	13.12	306.69	20.6	
3	YH1	NW China	660	2141	0.92	0.74	22.53	292.69	20.75	
4	YH2	NW China	660	2141	0.86	0.74	22.53	291.37	20.74	
5	MJ1	C China	600	1900	0.39	0.39	0.38	19.2	290.78	22.05
6	MJ2	C China	600	1900	0.36	0.38	0.38	19.2	291.31	22.05
7	XZ2	C China	1000	3099	0.55	0.57	0.59	19.1	274.11	20.98
8	JH1	E China	320	1025	0.5	0.41	0.34	15.19	307.1	21.51
9	JH2	E China	320	1025	0.48	0.4	0.34	15.19	302.47	21.51
10	ZS4	E China	350	1146	0.48	0.46		12.7	279.76	21.56
11	TC7	E China	630	1942	0.41	0.43	0.4	10.7	286.9	24.14
12	TC8	E China	630	1913	0.41	0.42	0.39	10.7	286.9	24.14

13	HS3	E China	1000	3130	0.47	0.44	17.9	281.39	21.33
14	HS4	E China	1000	3130	0.48	0.47	17.9	281.39	21.33
15	AQ3	E China	1000	2910	0.47	0.3	13.5	267.57	22.1
16	AQ4	E China	1000	2910	0.48	0.3	13.5	267.14	22.1
17	WZ1	E China	1050	3035		0.42	9.3	260.9	22.88
18	WZ2	E China	1050	3035		0.47	9.3	260.9	22.88

Electricity and heat cogeneration units

1	QD1	BTH	215	670	0.51	0.5	0.46	26.89	325.36	20.56
2	QD2	BTH	215	670	0.51	0.5	0.46	26.89	325.25	20.56
5	QD3	BTH	320	1025	0.51	0.49	0.46	26.89	295.99	20.56
6	QD4	BTH	320	1025	0.51	0.49	0.46	26.89	295	20.56
9	SH1	BTH	350	1175	0.45	0.43	0.41	13.75	290.52	21.77
10	SH2	BTH	350	1175	0.45	0.42	0.41	13.75	292.16	21.71
3	SH3	BTH	300	1025	0.45	0.42	0.4	14.67	263.28	22.07
4	SH4	BTH	300	1025	0.44	0.42	0.4	14.67	267.61	21.98
11	PS1	BTH	530	1650	0.45	0.44	0.49	13.53	293.86	22.19
12	PS2	BTH	530	1650	0.45	0.44	0.49	13.53	296.18	22.19

13	DZ3	BTH	660	2150	0.47	0.47	11	297.24	21.4	
14	DZ4	BTH	660	2150	0.48	0.46	11	296.94	21.4	
15	ZD1	N China	330	1018	0.39	0.43	31.7	299	16.29	
16	ZD2	N China	330	1018	0.39	0.38	31.7	299	16.29	
17	ZD3	N China	330	1018	0.39	0.42	31.7	299	16.29	
18	ZD4	N China	330	1018	0.4	0.4	31.7	299	16.29	
21	BD1	NE China	600	1913	0.19	0.17	0.16	9.18	296.83	15.11
22	BD2	NE China	600	1913	0.19	0.18	0.16	9.18	296.95	15.11
29	CD3	C China	660	2080	0.41	0.35	0.34	11.65	291.35	23.79
30	CD4	C China	660	2080	0.41	0.35	0.34	11.65	290.81	23.79

283 BTH = Beijing-Tianjin-Hebei; NE China= North East of China; NW China= North West of China; N China=North
284 of China; E China=East of China.

285 a. Power = designed power (electricity and/or vapor) generation capacity of turbine.

286 b. Annual average sulfur content in coal (as-received basis).

287 c. Annual average ash content in coal consumed in 2016 (as-received basis).

288 d. Consumed standard coal per KWh of power generation.

289 e. Annual average lower heating value in coal consumed in 2016.

290

291

292

293 **Table S5. ULE retrofit routes across 25 units**

Pollutant	Retrofitting route	Unit
NO _x	Adding or improving LNB	SH1, SH2, TC7, TC8, YH1, YH2, QD1, QD2, QD3, QD4, PS1, PS2, JH1, JH2, HS3, HS4, ZD1, ZD2, ZD3, ZD4
	Improving SCR	SH1, SH2, CD3, CD4, DZ3, DZ4, TC7, TC8, DG3, DG4, YH1, YH2, QD1, QD2, QD3, QD4, CD3, CD4, JH1, JH2, HS3, HS4, BD1, BD2, ZD1, ZD2, ZD3, ZD4
	Improving operation and coal quality	MJ1, MJ2, YH1, YH2, JH1, JH2
	Replacing WFGD by SFGD	QD1, QD2, QD3, QD4
SO ₂	Upgrading WFGD	SH1, SH2, ZS4, DG3, DG4, YH1, YH2, PS1, PS2, JH1, JH2, BD1, BD2, ZD1, ZD2, ZD3, ZD4
	Replacing WFGD by SPC	HS3, HS4, TC7, TC8
	Improving operation and coal quality	MJ1, MJ2, CD3, CD4, JH1, JH2, PS1, PS2
PM	Upgrading ESP	SH1, SH2, MJ1, MJ2, TC7, TC8, YH1, YH2, CD3, CD4, BD1, BD2, ZD1, ZD2, ZD3, ZD4, PS1, PS2
	Adding LLT ESP	SH1, SH2, TC7, TC8, YH1, YH2, JH1, JH2
	Adding PM filter	QD1, QD2, QD3, QD4

Adding WESP	SH1, SH2, TC7, TC8, CD3, CD4, JH1, JH2
Adding SPC	TC7, TC8, HS3, HS4
Upgrading demister in WFGD	YH1, YH2, QD1, QD2, QD3, QD4, PS1, PS2, JH1, JH2, ZD1, ZD2, ZD3, ZD4, MJ1, MJ2

295 **Table S6. Accuracy test results by independent manual measurements for flue**
 296 **gas flow rate measurements in the CEMS.**

Unit	Relative error with respect to manual measurements ^a (%)
CD3	2.90
CD4	5.45
HS3	1.04
HS4	4.14
ZS4	1.20
QD1	±8.00 ^b
QD2	±8.00 ^b
QD3	±8.00 ^b
QD4	±8.00 ^b
XZ2	-7.77
JH1	-4.50
JH2	-6.80
AQ3	1.60
AQ4	-3.40
PS1	8.50
PS2	2.90
WZ1	-7.20
WZ2	-7.50
MJ1	7.80
MJ2	8.20
TC7	-3.16
TC8	-2.58
ZD1	1.50
ZD2	0.70
ZD3	-10.50
ZD4	7.20
SH1	11.30
SH2	-10.00
SH3	-10.20
SH4	-10.30
DZ3	±12.00 ^b
DZ4	±12.00 ^b
BD1	2.00
BD2	-5.90
DG3	±12.00 ^b
DG4	±12.00 ^b
YH1	±12.00 ^b
YH2	±12.00 ^b

-
- 297 a. The first nine units were enforced with stricter requirements for sensor quality: within 5% of
298 the manual measurements when manually measured flow rates were above 10 m/s, or within
299 8% when measured flow rates were below 10 m/s. For other units, the requirements were as
300 follows: within 10% for rates above 10 m/s and within 12% for rates below 10 m/s.
- 301 b. These units complied with the sensors requirements, although the detailed test results are not
302 available.
- 303

304 **Table S7. Emissions factors for NO_x, SO₂, and PM from Chinese power plants**
 305 **in the literature and this study**

Reference	EF (g/kg of St. coal)	Control device	Year	Methodology
NO _x				
INTEX-B; Zhang et al. (2009)	7.1	Asian average	2006	Top-down
MEIC; Liu et al. (2015)	5.26	China average	2010	Unit-based and bottom-up
MEIC; Zheng et al. (2018)	4.43 3.79	China average	2015 2016	
Zhao et al. (2011)	4.70-11.2	LNB	before 2010	Field measurement-based
Ma et al.	0.23-0.73	LNB+SCR	2015	Field measurement-based
Spath et al.(2000)	0.302 ^a	SCR (gas-fired plant)	1997 (USA)	Unit-based
Jarre et al.	0.18-0.39 ^a	SCR (gas-fired plant)	2014	Continuous field

(2016)			(Italy)	measurement-based
Song et al. (2018)	2.15 ^a	LNB (gas-fired plant)	2014 (China)	Case study
Wang et al. (2016)	0.12 ^a	SCR (gas-fired plant)	2015 (China)	Case study
This paper	0.48	LNB+SCR	2015-2017	Continuous field measurement-based
SO ₂				
INTEX-B; Zhang et al. (2009)	15.6	Asian average	2006	Top-down
MEIC; Liu et al. (2015)	4.89	China average	2010	Unit-based and bottom-up
MEIC; Zheng et al. (2018)	3.39 2.23	China average	2015 2016	
Zhao et al. (2011)	0.9S ^b	WFGD	before 2010	Field measurement-based
Spath et al.(2000)	0.197 ^a	No control (gas-fired plant)	1997 (USA)	Unit-based

Song et al. (2018)	0.007 ^a	No control (gas-fired plant)	2014 (China)	Case study
Wang et al. (2016)	0.005 ^a	No control (gas-fired plant)	2015 (China)	Case study
	0.27 (0.5S ^b)	WFGD		
This paper	0.10 (0.25S ^b)	SPC	2015-2017	Continuous field measurement-based
	0.02 (0.05S ^b)	SFGD		
PM				
INTEX-B; Zhang et al. (2009)	1.2 (PM2.5)	Asian average	2006	Top-down
MEIC; Liu et al. (2015)	0.83(PM10)	China average	2010	
MEIC; Zheng et al. (2018)	1.13 1.07	China average	2015 2016	Unit-based and bottom-up
Zhao et al. (2011)	0.0231A ^c	ESP+WFGD	before 2010	Field measurement-based
Sui et al. (2016)	≤0.002A ^c	LLT ESP+WFGD+WESP	2015	Case study

Spath et al.(2000)	0.006 ^a	No control (gas-fired plant)	1997 (USA)	Unit-based
Song et al. (2018)	0.028 ^a	No control (gas-fired plant)	2014 (China)	Case study
Wang et al. (2016)	0.0003 ^a	No control (gas-fired plant)	2015 (China)	Case study
This paper	0.05 (0.0027A ^c)	ESP+WFGD (or SFGD)	2015-2017	Continuous field measurement-based
	0.02 (0.0019A ^c)	SPC		
	0.04 (0.0025A ^c)	LLT ESP+WFGD		
	0.03 (0.0028A ^c)	ESP+WFGD+WESP		
	0.03 (0.002A ^c)	LLT ESP+WFGD+WESP		
	0.01 (0.00078A ^c)	LLT ESP+SPC+WFGD+WESP		

306 ^aThe original gas-fired plants EF values presented in units of g/kWh were converted
307 to g/kg by using the annual average standard coal burned per kWh of electricity in
308 2015 in China (0.315 kg/kWh).


309 ^bEF are expressed as proportional to the annual average sulfur content.

310 °EF are expressed as proportional to the annual average ash content.

311

312

313




314

315 **Figure S1.** Map of power plants sampled in this study.

316

317

318



319

320 **Figure S2.** EF and removal efficiency as a function of the sulfur content in coal,
321 averaged over all units implementing the same ULE technologies. Error bars represent
322 one standard deviation across the units.

323